HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____ 1
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Richard Drum OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5-10-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Morrow Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	4-6% L	0-4"	l	gr	1:1 / vfr	.1940 WETNES CONDITION	S
		4"-42"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	P.S.
		42"-48"	Saprolite			.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	3-5% L	0-5"	l	gr	1:1 / vfr	.1940 WETNES CONDITION	S
		5"-36"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	P.S.
		36"-43"	C/saprolite mix			.1944 RESTRICTIVE HORIZON	S
		43"-49"	saprolite			.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	3-5% L	0-7"	l	gr	1:1 / vfr	.1940 WETNESS CONDITION	S
		7"-48"	c	sbk	1:1 / fr.	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4						.1940 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1940 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35gpd/ft²
OTHER FACTORS(.1946): SYSTEM TYPE:
EVALUATED BY: Michael J. Dennis OTHER(S) PRESENT:
COMMENTS:

DRAFT