10773.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR FRED SIGMON DATE 1-17-90 PERMIT NO. SM-7-A-6.

PHONE: Business _____ Home _____

LOCATION Will be approx. one mile from Mott. Rd-T Right 2nd 250 yards on R. S. R. No. _____

SUBDIVISION NAME STONEWOOD DEV. LOT NO. 32 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Loam-Suitable.
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 2-32 min/in.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-8%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 12+
			Rock or other impervious formations None observed.

Lot Area 5.34 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Lineal Ft. 240
Depth of Stone in Lines 24

Water Supply: Individual ( )
Public (✓)

Installed by Durell Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Stuart Braun

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Stuart Braun DATE 1-17-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold