10642.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GEORGE M. MYERS DATE 11-1-89 PERMIT NO 89-7-A-34

PHONE: Business _____ Home _____

LOCATION Exit 47 west to Mocksville Rd. go to Rock Hill Rd. turn on 1st dirt rd. - 3rd house

S. R. No. _____

SUBDIVISION NAME STONEWOOD DEV. LOT NO. 34 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Acpk.

Character & Porosity of Soil Prev. Suitable.


Percolation Rate Prev. Tested.

Topography Level Lot

Depth to Water Table _____

Rock or other impervious formations None Observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Lineal Ft. 240

Depth of Stone in Lines 1st

Water Supply: Individual ( )
Public (✓)

IMPROVEMENTS PERMIT BY Steve Brown

Installed by Darrell Lowery

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-1-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold