11895.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR DERICK HOLLER DATE 8-31-90 PERMIT NO 811-7-A-13.

PHONE: Business _____ Home _____

LOCATION Mt. Mill Rd. to Hamptonville - go approx. 3/4 mi. to T.L. into dev. - stay straight - reserved, left. S. R. No. _____

SUBDIVISION NAME STONEWOOD II LOT NO. 13. SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2 Character & Porosity of Soil Brown Suitable.
Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 30 Min/In
Auto. Dishwasher Yes ( ) No (✓) Topography Gently Rolling
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+
Site Suitable Yes (✓) No ( ) Rock or other impervious formations None observed.
Lot Area Ample.


_____ Basement with Plumbing BRANCH Basement Without Plumbing ✓ No Basement

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Lines Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Rudy Lipscomb Eldon Eller

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____



Plot of System

IMPROVEMENTS PERMIT BY Steve Braun

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Braun DATE 8-31-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold