HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jame Elmore OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: 3-29-99
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: Shady Rest Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	4-6% L	0-3"	cl	gr	1:1 / vfr	.1942 WETNES CONDITION	P.S
		3"-48"	C	Sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S
						PROFILE LTAR	.35
2	4-6% L	0-2"	cl	gr	1:1 / vfr	.1942 WETNES CONDITION	P.S.
		2"-42"	c	Sbk	1:1 / fr	.1943/.1956 SAPROLITE	42"-↑
		42"-↑	saprolite			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	3-5% L	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S
		5"-48"	c.	Sbk	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) ____ SYSTEM TYPE ____
EVALUATED BY Michael Dennis OTHER(S) PRESENT: Install interceptor drain around system.
COMMENTS: Water filled up hole from bottom at 36" (Lateral water movement)

DRAFT