IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # REPAIR PIN # 4703-65-9921 DATE DECEMBER 23, 2009

OWNER or APPLICANT BOBBY FRANKLIN TRAVIS PHONE: Business 704-450-9999 Home:

OWNER or APPLICANT ADDRESS 121 GYPSY DRIVE, STATESVILLE, NC 28677

LOCATION / DIRECTIONS US 70 WEST, TL SHADY REST ROAD, TR GYPSY DR (TANKS ON (R); DRAINFIELD ON (L))

SUBDIVISION TRAVIS MHP BLOCK / SECTION LOT # H, 1, 2, 3 LOT AREA 4.3 ACRES DESIGN FLOW 1080 L.T.A.R. 0.30 GPD/FT2

2 X

Septic Tank 1500 Gallons: STB 1014/1014 Date 2-19-10/1-16-10

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 2 No Lines 12 Linear Feet 900

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☑ Repair ☐ Expansion System Type I II (III) IV V VI

System Description:

Repair System Description: 25% REDUCTION, GRAVITY

Maintenance Agreement Required ☐ YES ☑ NO

☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 9

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☒ Public ☐ Community

Comments / Conditions

Comments / Conditions

INITIAL SITE SKETCH

1. EASEMENT REQUIRED FOR LOCATING DRAINFIELD ONTO PIN# 4703-75-3848 PRIOR TO A.C.
2. ABANDON EXISTING WELL ADJACENT TO HOUSE ACCORDING TO 15A NCAC 02C .0113 PRIOR TO A.C.
3. RELOCATE EXISTING WATER LINE MINIMUM TEN FEET FROM PROPOSED DRAINFIELD.
4. INSTALL SUPPLY LINE MINIMUM 30" DEEP BENEATH AREAS SUBJECT TO VEHICULAR TRAFFIC.
5. INSTALL 25% REDUCTION SYSTEM ON CONTOUR AS FLAGGED USING SERIAL DISTRIBUTION.
6. THIS WASTEWATER SYSTEM REPAIR CONSISTS OF TWO SEPARATE TANKS & DRAINFIELDS SERVING TWO DWELLING UNITS EACH.
7. SEE ATTACHED REPAIR SITE SKETCH FOR SPECIFIC LOCATION REQUIREMENTS.

AS BUILT SKETCH

TRAVIS MHP AS DRAWN ON SITE PLAN.

Site: 104, 125, 127 + 133 Bobby Map

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 1-5-10; 5/5/10 Installed by: Rowan Septic Service

Improvement Permit by: STEVE HEARICK Date 12-23-09 Operation Permit by: [signature], R.S. Date: 17 June 10

Authorization to Construct by: [signature] Date 5-5-10 Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant

REPAIR SITE SKETCH
PIN# 4703-65-9921
TRAVIS MHP

