IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☑ STATESVILLE OFFICE 704-878-5305 ☐ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 167833 PIN # 4703-65-9921.125 DATE 29 July 2011

OWNER Synergy Asset Group APPLICANT: Mark Odum PHONE: Home/Cell # (704) 878-2550 Business #

SITE ADDRESS 125 Bobbi's Loop OWNER / APPLICANT ADDRESS

SITE DIRECTIONS Old Mtn Rd. from I-40W. TR Hwy 70 - TL Bobbi's Loop - on Rt.

SUBDIVISION Hickory Ridge BLOCK / SECTION LOT # 3 LOT AREA 4.3 Acres DESIGN FLOW 240 gpd L.T.A.R. 0.3

24

Septic Tank	1500	Gallons: STB		Date	☐ New System	☐ Repair	☐ Expansion System	Type I II (III) IV V VI	☑ Residence	No. Bedrooms	2	Water Supply
Pump Tank		Gallons: PT		Date	System Description:	25% Reduction			☐ Business	No. Persons		☐ Private
Pump Make		Model		Serial #	Repair System Description:				☐ Other	No. Employees		☑ Public
No. Nitrification Fields:	2	No. Lines	12	Linear Feet	900	Maintenance Agreement Required ☐ YES ☑ NO			☐ Slab	☑ Crawl Space		☐ Community
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth		☑ GRAVITY ☐ PRESSURE			☐ Basement w/plumbing	☐ Basement w/o plumbing		

Comments / Conditions

INITIAL SITE SKETCH

AS BUILT SKETCH

Replace mobile home on Lot #3 received 17 June 10.

A Copy of CP attached.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☐ ***IMPROVEMENT PERMIT*** *with ~~plat valid without expiration.~~ site plan valid 60 mo.* ☐ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: M. Odum Date 8-1-11 Installed by:

IMPROVEMENT PERMIT by: REHS Date OPERATION PERMIT by: REHS Date

AUTHORIZATION TO CONSTRUCT by: REHS Date Existing System Inspected by: REHS Date 29 July 2011

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant