DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Bob Tiner
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: SFR APPLICATION DATE: ___ DATE EVALUATED: 4-3-96
LOCATION OF SITE: Lot 5 Suzanne Ln PROPOSED DESIGN FLOW (.1949): 360 GPD PROPERTY SIZE: 1.5 A
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: NO
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 11 6%	0-12	SAND LCL	FR					
		12-23	SAND R LGR	FR					
		23-48	MSCL VR CL	FI					
			Saturated	Low Chroma					
2	L 4-6%	0-17	SAND LCL	FR					
		17-24	SAND R LGR	FR					
		24-48	MSCL VR CL	FI					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity Conv.	Gravity Pressure Comp.
Site LTAR	~.35	.35

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS -
EVALUATED BY: DH Hamm
OTHER(S) PRESENT: Bob Tiner