DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jason Boat APPLICANT: _____
ADDRESS: 157 Suzanne Ln APPLICATION DATE: _____ DATE EVALUATED: 6/20/00
PROPOSED FACILITY: 4BDR 3BD PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .64
LOCATION OF SITE: 70W TL Shelly Rd TR Suzanne on (L) after 9th M PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	7-12% CVL	0-8	SBK / l	FR NP SS					
		9-23	SBK / cl	FI SS SP					
		24-32	SBK / FI sc l	FR SS SP					.4
		33-48	GR / c l	FR SS NP					
2	7-8 NCVL (T)	0-5	GR / l	FR NP SS					
		6-24	SBK / cl	FI SP SS					
		25-33	SBK / sc l	FR SP SS					
		34-49	GR / c l	VFR NP SS					.4
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____