1589.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR WILLARD AUTON DATE 6-22-90 PERMIT NO. T&C 91-A-84.

PHONE: Business _____ Home _____

LOCATION Hwy 70 East to White Oak Rd. - T.L. on Shady Rest Rd. - T.R. on Bygone Lane - 1st lot on left.

S. R. No. _____

SUBDIVISION NAME HAWKS SUBD. LOT NO. 7 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Character & Porosity of Soil Prev. Suitable.

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate _____


Auto. Dishwasher Yes ( ) No (✓) Topography _____

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed

Lot Area 28,677 sq. ft.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Kenny Pearson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-27-90

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold