Bender, Brown, Elder

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rick Grezory DATE 8/22/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. Past White Oak. T.L. on Rd #1370 at Travis Trailer Park. T.L. 1st Drive. 1st House on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 Sq ft

Character & Porosity of Soil Prov. Suitable (Por)
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 270
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts and all surface water possible should be diverted away from tank and lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8/22/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold