DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 2 of 2
PROPERTY ID #: 470380799
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ralph Teasters
ADDRESS: 102 Paddington Ct.
PROPOSED FACILITY: 3BR SFD
PROPOSED DESIGN FLOW (.1949): 360gpd
LOCATION OF SITE: 138 Rinaldi Acres
WATER SUPPLY: • Private • (Public) • Well • Spring • Other N/A
EVALUATION METHOD: • (Auger Boring) • Pit • Cut
TYPE OF WASTEWATER: • (Sewage) • Industrial Process • Mixed

APPLICATION DATE 2-1-13
DATE EVALUATED 2-21-13
PROPERTY SIZE: 0.32 acres
PROPERTY RECORDED: Yes

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
5	HS	0-10	SC SBK	Fr Mod SE	>48"	>48"	>48"	>48"	PS 0.25
		10-33	C ABK	Fi Mod SE					
		33-48	CL Red WABK	Fi Mod SE					
6	HS	0-9	SC SBK	Fr Mod SE	>48"	>48"	>48"	>48"	PS 0.25
		9-34	C ABK	Fi Mod SE					
		34-48	CL WABK	Fr Mod SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	IV
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: N/A

COMMENTS: N/A