DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 2
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jerry Price APPLICANT: Jerry Price
ADDRESS: 239 Lewis Ferry Rd Statesville NC APPLICATION DATE: 6.11.99 DATE EVALUATED: 6 24 99
PROPOSED FACILITY: 3 Bdrm Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.36 Ac
LOCATION OF SITE: Lot 45 Three Oaks off Ellenstreet off Old Mt Rd PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 12-15%	0-9	SBK C	FI		24"			U
		9-24	SBK C SAP Fracture	FI-FR					
		24-48	SAP						
2	L 15 18%	0 20	SBK C	FI		20"			U
		20+34+	SAP	FR					
3	L 2-5%	0 36	SBK C	FI-FR		36"			PS .3+
		36+	SAP	FR					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): U
EVALUATED BY: L Potts
OTHER(S) PRESENT: Owner (Price)