DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: TRENTON
4703 88 6597

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JERRY PRICE APPLICANT: SAME
ADDRESS: 05 N CYPRESS ANDREWS DR APPLICATION DATE: 12/6/2002 DATE EVALUATED: 01/17/03
PROPOSED FACILITY: 3BR HOME PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .69 ACRE
LOCATION OF SITE: THREE OAKS LOT 42 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	4% Linear	0-12"	l, wk, gr	fr, ns, np, smp		>48"			PS .35
		12-36"	cl, med, sbk	fr, s, p, smp					
		36-42"	c, med, sbk	fi, ss, sp, smp					
		42-48"	c, sap mix, wk	fr, ss, sp, smp					
2	4% Linear	0-8"	l, wk, gr	fr, ns, np, smp	30" SLOW MOTTLES	>48"			PS .3
		8-32"	cl, med, sbk	fr, ss, sp, smp					
		32-42"	c, med, sbk	fi, s, p, smp					
		42-48"	c, sap mix, wk	fr, ss, sp, smp					
3	6% Linear	0-2"	scl, wk, gr	fr, ns, np, smp		<24"			
		2-12"	c, med, sbk	fi, ss, sp, smp					
		12-24	c, med, sbk	fr, ss, sp, smp					
		24"	ROCK						
4	6% Linear	0-2"	scl, wk, gr	fr, ns, np, smp		>48"			PS .35
		2-24"	c, med, sbk	fi, s, p, smp					
		24-48"	c sap mix	fr, ss, sp, smp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	25% REDUCT	50% REDUCT
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: JERRY PRICE