IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gospel Way Baptist Church DATE 2-26-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Hwy 64-70 W. Tk. on Rd 1370
Church on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area 1 Acre

Character & Porosity of Soil Poor Soil
Percolation Rate _____
Topography Slight slope Low?
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: Poor Soil found 1st 35' of ditch. Downspouts and foundation drains need to be diverted away from Tank + lines. Basement was dug approximately 2' deeper than it should be. Better system could have been had if original plan had been followed

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 2-26-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold