2946

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RAY BENFIELD DATE 3-20-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 - West to White Oak - T.L. + then T.R. on Lewis Ferry Rd. then T.L. on Pinedale Heights Rd - 3rd mobile home on (R). S. R. No. 1

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2-3 No. Bathrooms 1-2 Character & Porosity of Soil Prev. Suitable


Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 5 min/1 in.

Auto. Dishwasher Yes ( ) No (✓) Topography 2-3%

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations Not observed.

Lot Area 20,000 sq. ft.



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Roger Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Dept of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-20-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 1, 1989 23:04