ON OF ENVIRONMENTAL HEALTH
E WASTEWATER SECTION

COUNTY: _____

# SOIL/SITE EVALUATION
## for ON-SITE WASTEWATER SYSTEM

ER: Jerry Price APPLICANT: _____
LESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
OSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
TION OF SITE: _____ PROPERTY RECORDED: _____
ER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
LUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

| .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|
| Linear 4% | 0 to 48 | C | SEAP Firm | 1 | | | | .125 |
| Linear 4% | 0 to 48 | C | SEAP Firm | | | | | .25 |
| Linear to Nose 6% | 0 to 24 | C | | | | | | .125 LPP |
| | 24" | Rock & Sap | | | | | | |
| Linear 6% | 0 to 24 | C | | | | | | .125 LPP |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | | |
| System Type(s) | | |

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____