LEGEND

use the following standard abbreviations

DSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL 1955 LTAR	LPP 1997 LTAR	MINERALOGY/ CONSISTENCE	STRUCTURE
Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive)	G (Single Grain)
Convex Slope)		LS (Loamy Sand)			SEXP (Slightly Expansive)	M (Massive)
rainage Way)					EXP (Expansive)	CR (Crumb)
Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
Flood Plain)		L (Loam)				SBK (Subangular Blocky)
Foot Slope)	III	SI (Silt)	0.6 - 0.3	0.3 - 0.15		ABK (Angular Blocky)
ead Slope)		SICL (Silty Clay Loam)				PL (Platy)
near Slope)		CL (Clay Loam)				PR (Prismatic)
ose Slope)		SCL (Sandy Clay Loam)			MOIST	WET
idge)		SILC (Silt Loam Clay)				
ioulder Slope)					VFR (Very Friable)	NS (Non-sticky)
rrace)	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SIC (Silty Clay)			FI (Firm)	S (Sticky)
					VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None		EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

ES

UZON DEPTH	In inches below natural soil surface
TH OF FILL	In inches from land surface
TRICTIVE HORIZON	Thickness and depth from land surface
ROLITE	S(suitable) or U(unsuitable)
WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color and designation
SSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

uation of saprolite shall be by pits.

g-term Acceptance Rate (LTAR): gal/day/ft²

Show profile locations and other site features (dimensions, reference or benchmark, and North).

