28411

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR HAROLD LILLY DATE 8-18-88 PERMIT NO. 14A

PHONE: Business _____ Home _____

LOCATION Hwy 64 W - 7 Miles past White Oaks - T.L. on Holman Rd. - 1st Stop Sign - Double wide, straight access rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

DOUBLEWIDE


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prov. Suitable.	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	40 Min/Inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 - 6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +	
			Rock or other impervious formations	none observed.	

Lot Area 2 acres.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Bill Culbertson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Utility Bldg. to be placed as shown.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-18-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold