DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Randall

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Scott Feinster APPLICANT: ___
ADDRESS: 123 Lambert Lane Statesville APPLICATION DATE: 2-23 2000 DATE EVALUATED: March 10 2000
PROPOSED FACILITY: 3 Bdrm Mod. PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: ~36
LOCATION OF SITE: Hwy 70 W (L) Holman (R) Lambert 3rd Lt on Rt PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	S L 10-12%	0-18	CL						PS .3
		18-24	SAB C	FR SS Exp					
		24-46	SB C w/ Rock	FR					
		46+	Slpl c	FR VFR					
2	L-S 8-10%	0-10	SAB C	FR					PS .3
		10-24	SAB^W CL	FR SS					
		24-38	SAB C w/ Rock	FR					
		38-42	Slpl	VFR					
		42+							
3	L FP 10-12%	0-28	SAB^W C	FR	Soil Fold at Rock 2				US Low Fert & Thin Mass
		28"							
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	25% Sprd	Rep 50%
System Type(s)	~	~
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Joe Poteat
OTHER(S) PRESENT: ___