IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR
OWNER OR CONTRACTOR GEORGE BURROW DATE 12/13/91 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION I-40 W, TL OLD MOUNTAIN RD, TR LEWIS FERRY RD, TR SHADY REST ROAD, 1ST MH ON (R) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other REPAIR


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area AMPLE

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table EXISTING
Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by JAMES HUDLER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE BROWN

COMMENTS: NEW "SANITARY TEE" INSTALLED IN TANK.
NEW D. BOX INSTALLED.
NEW LINES FEEDING FIRST.

CERTIFICATE OF COMPLETION BY STEVE HENRICK DATE 12/13/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold