04947

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JACK CLANTON DATE 7-2-86. PERMIT NO.

PHONE: Business Home


LOCATION Bentley Church Rd. off old Mtn. Rd. - T. L. on Mock Mill Rd. - 3/8 mi. on left. S. R. No.

SUBDIVISION NAME MOCK MILL RUN LOT NO. 7 & 45 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1-2 Character & Porosity of Soil Prov. Suitable.
Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 1 - 5 min./1 in.
Auto. Dishwasher Yes ( ) No (✓) Topography 2 - 6%
Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+
Site Suitable Yes (✓) No ( ) Rock or other Impervious formations none observed.
Lot Area Ample

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Dennis Hallifax

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-2-86.

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold