08542

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CATHY WOODSIDE DATE 10-6-88. PERMIT NO. 14A.

PHONE: Business _____ Home _____

LOCATION Bethel Church Rd. off Hwy 115 N. Pl. - stay straight 2.5 mi. turn R. 1st house on R. - 1st house on right after Bethel Church Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2 Character & Porosity of Soil Gray Sandy Clay

Garbage Disposal Unit Yes ( ) No (X) Percolation Rate 30 min/1 in.


Auto. Dishwasher Yes ( ) No (X) Topography 2-6%

Auto. Wash. Machine Yes (X) No ( ) Depth to Water Table 10+

Site Suitable Yes (X) No ( ) Rock or other impervious formations surface rock

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field: 3

No. of Lines

Sq. Ft. 900 Lineal Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (X)

Installed by Dennis Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Edna Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Edna Brown DATE 11-2-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in applying for Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 3, 1989 17:29