Repair

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Jimmy Winters DATE 5-7-93 PERMIT NO. Repair

PHONE: Business _____ Home 872-7084

LOCATION I40W TR Old Mtn. Rd. TL Island Ford Rd 6th house on L.

S.R. No. _____

SUBDIVISION NAME NA LOT NO. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ≈1.0 acre

Soil Characteristics Existing


Application Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank Existing 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200'

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Well

Public ☐

Installed by Harry Reep.

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Michael J. Dennis

COMMENTS Fed existing Drain Lines first, Repair second.

CERTIFICATE OF COMPLETION BY Michael J. Dennis DATE 5-7-93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold