IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 1st Trailer
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. R. Munday DATE 4/10/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. T.R. on old Mountain Rd. T.L. at Blaulah Baptist Church T.L. at Byers Garage. T.R. 1st drive. 1st Trailer on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area Acreage

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: No Well on Property at this time

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/10/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold