02942

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wade Marett DATE 4-18-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I40 west - T.L. on Old Mtn. Rd. - 1st T.R. on Beulah Church Rd - go back under I40 - 1st dirt road on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 95 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2 Character & Porosity of Soil Fair Suitable

Garbage Disposal: Yes ( ) No (✓) Percolation Rate 3 min/in


Auto. Dishwasher: Yes (✓) No ( ) Topography 2-6% slope

Auto. Wash. Machine: Yes (✓) No ( ) Depth to Water Table 10+

Site Suitable: Yes (✓) No ( ) Rock or other impervious formation none observed

Lot Area 4.5 acres

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Lineal Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 4-18-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 3, 1989 7:01

473 & 48 2194 Terri Reagan

198 Harriet Lane