IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pressley Rowe DATE 4-11-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Island Ford Rd. 2nd House on R. past Bradford X Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq ft

Character & Porosity of Soil Red Clay
Percolation Rate 20 Min/Inch
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Henry Rowe

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-11-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold