Flake Pratt Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Sharp DATE 11-1-74 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Old Mountain Rd above Bradfords X Road T.R. on 1643 - House at end of Road. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Red Clay


Percolation Rate _____

Topography Slope Low

Depth to Water Table None

Rock or other impervious formations _____

Lot Area 20,000 sq ft +



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Robert Hoke

R.E. Foy

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts and all surface water possible should be diverted away from lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11-1-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold