IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Don Davidson DATE 10-15-73 PERMIT NO. _____

PHONE: Business _____ Home 872-5057

LOCATION 218 Mountain Rd East Bradford & Rd. T.R 1st dirt Rd. Beside Horse Barn - House on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2-

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 22,500 sq ft

Character & Porosity of Soil Red Clay
Percolation Rate No Perc Test Made
Topography Slightly Sloping to Front
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Ostwalt

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: Well 72' from Tanks + Lines

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 10-23-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold