IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date _____ 194__

Owner Frank Beaty Address _____

Tenant _____ Address _____

Installed by Clyde H. Mc Address Statesville Rt

Location of Property near Bullocks Crossroads

Kind of Tank Concrete Capacity 500 Length of trench 150 x 3 x 2


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 6-1-55 194 Approved (X) Disapproved ( )

Remarks: Approved for automatic clothes washer & disposal unit.

First five feet of line from outlet should be of cast iron soil pipe.



Harry L. Isenhour
Sanitarian

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.