IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Henry P. Dameron DATE 16 Oct 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I 40 W to Old U.S. 21 S to SR # 1006 at Bradford Crossroads T.L. to SR # 1521 on Left Dameron Home on Left S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Custer Mod Pavement

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	60 min
Auto. Wash. Machine	Yes ( )	No ( )	Topography	Type 3 on top of Hill
Site Suitable	Yes ( )	No ( )	Depth to Water Table	4'
			Rock or other impervious formations	none

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 650 Linear Ft. 260
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Henry Lee

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Lem Howard DATE 16 Oct 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold