IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RALPH YOUNT DATE 7-21-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I40 west – T.L. on Old Mtn. Rd. – then T.R. on Zodiac Rd just across I-40 – 3rd business on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business (✓) Other Showroom for furniture

No. Bedrooms — No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )
Lot Area Ample

Character & Porosity of Soil Prev. Suitable
Percolation Rate Septy. ft.
Topography 2-6%
Depth to Water Table 10+
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: No parking or driving over S.T. system. Seed grass back over entire system. Recommended to create diversion ditch above drain lines to keep surface water off them. No more than 8 bedrooms indicated.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-21-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold