SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES — DRAFT
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#: BM-9 A 10 ~~#~~
DATE: 11-16-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: [illegible] OWNER__ AGENT: ✓ PHONE: 872-6645
ADDRESS: [illegible] APPLICATION DATE: 11-2-95 DATE EVALUATED 11-16-95
STATESVILLE NC 28677 PROPOSED FACILITY: 5BR D/W MH
PROPERTY SIZE: 0.623 ACRE
LOCATION OF SITE: [illegible] LOT 11
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other____ EVAL. METHOD: Auger Boring ✓ Pit____ Cut____

PROFILE #	.1940 LANDSCAPE POS. SLOPE(%)	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	L	0-98	C	SBK	VT/ST			.1942 Wetness Cond. 5
	12%	@						.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3
	L	0-98	C	SBK	VT/ST			.1942 Wetness Cond. 5
	32%							.1943 Depth/.1956 Sapr. 5
								.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3
								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

ACCEPTABLE SPACE (.1945) 5 OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE CONVENTIONAL GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²

EVALUATED BY: [illegible] OTHER(S) PRESENT: [illegible] LOT 11 PUNGE, LES JACKSON

COMMENTS: LOT TO BE COMBINED WITH LOT #11 WHICH WAS DETERMINED TO BE UNSUITABLE

00203