IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ralph G. Yount DATE 5/29/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION I-40 W - T.L. on old Mountain Rd. Building on L. just before Beaulah Baptist Church S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business (✓) Other _____

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Prov Suitable
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	slight Slope
Site Suitable	Yes ( )	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area _____



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 1800 Linear Ft. 600
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tanks

IMPROVEMENTS PERMIT BY E.A.S & R.W.J.

COMMENTS: All Surface water to be diverted away. This System designed for No More than 40 People and No industrial Waste

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5/29/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold