DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 8M-9-A-12
DATE: 11-16-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: TONY A DIRSE
ADDRESS: 221 LAKE BOARD ROAD, STATESVILLE, NC 28677
OWNER__AGENT: ✓ PHONE: 872 6695
APPLICATION DATE: 11-29-95 DATE EVALUATED 11-16-95
PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 0.623 ACRE
LOCATION OF SITE: PINE RIDGE ESTATES, LOT 11-12
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other____ EVAL. METHOD: Auger Boring ✓ Pit____ Cut____

PROFILE #	.1940 LANDSCAPE POSITION SLOPE%	HORIZON DEPTH (IN)	.1941 (1) TEXTURE	.1941 (2) STRUCTURE	.1941 (3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS	
1	L	0-9	C	SBK	1:1/F2			.1942 Wetness Cond.	S
	8%							.1943 Depth/.1956 Sapr.	S
								.1944 Restrictive Hori.	S
								.1948 Profile Class.	PS
								Profile LTAR	0.35
2	L	0-9	C	SBK	1:1/F2			.1942 Wetness Cond.	S
	8%							.1943 Depth/.1956 Sapr.	S
								.1944 Restrictive Hori.	S
								.1948 Profile Class.	PS
								Profile LTAR	0.35
3								.1942 Wetness Cond.	-
								.1943 Depth/.1956 Sapr.	-
								.1944 Restrictive Hori.	-
								.1948 Profile Class.	-
								Profile LTAR	-
4								.1942 Wetness Cond.	-
								.1943 Depth/.1956 Sapr.	-
								.1944 Restrictive Hori.	-
								.1948 Profile Class.	-
								Profile LTAR	-

AVAILABLE SPACE (.1949): LIMITED OTHER FACTORS (.1946): NONE SITE CLASSIFICATION (.1948): PS
SYSTEM TYPE: ~~REPAIR~~ CHAMBERED GRAVITY LONG-TERM ACCEPTANCE RATE(S): 0.35 GPD/FT2
EVALUATED BY: SCOTT HASPICK OTHER(S) PRESENT: ERNEST H RUNGE (LES) JACKSON
COMMENTS: USE CHAMBER SYSTEM DUE TO 50' SETBACK FROM STREAM.

002048