IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. A. Sample DATE 4/29/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Island Ford Rd to West Iredell High School Road* 1678
T.R. House on Rt. Next to last lot. S. R. No. 1678

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 170 X 320

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slight Slope to back Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tanks Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts and all surface water should be diverted away from septic tank and lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/24/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold