IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR: IVA HERZOG DATE 11-14-90 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 90 W to L on Tigerdale Rd - white house on R just past Redeemer Luth. Ch.

S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other Repair


No. Bedrooms No. Bathrooms

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No (✓)
Site Suitable	Yes (✓)	No ( )

Lot Area Ample

Character & Porosity of Soil
Percolation Rate
Topography
Depth to Water Table Repair
Rock or other impervious formations

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plat of System

Size of Tank EXISTING Gals.
Nitrification Field
No. of Lines 2
Sq. Ft. 120 Lineal Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Barry Lignon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Old drainfield abandoned. New fee installed inside of Tank for new drain lines. Tank pumped.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-14-90

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold