IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronald Bayfield DATE 8/25/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Rd about Bradford X Rd. T.R. on Rd 1520 T.R. on 1652. House on Rt Back off of Rd. S. R. NO. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prof Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 - 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Level
			Rock or other impervious formations	None

Lot Area 2½ Acres



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS All surface water should be diverted away from Tank + Lines

CERTIFICATE OF COMPLETION BY E. H. Stevenson DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold