IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edminston-Brinkley Bldr DATE 11-9-73 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION I-40 W to old Mountain Rd. T.R. Then T.R. on Rd # 1520 (Massey Rd) House on Rt. 2nd house to your Rd # 1652 S. R. No. 1520

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


old O. M. Perry Property

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	None
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 100 X 200



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Lackey Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: House under Construction Prior to Oct. 1st 1973
No improvements Permit issued.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 11-9-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold