09739

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GEOFFREY MOOSE DATE 5-18-89 PERMIT NO. 89

PHONE: Business _____ Home _____

LOCATION Hwy 70 W. past Log Bradford Rd approx 3/4 mi. on (R) - Enter 1st - stay straight to Stockton Farms S. R. No. _____

SUBDIVISION NAME ALEXANDER FARM DEV. LOT NO. 23 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Acpb

Character & Porosity of Soil Prov. Suitable.
Percolation Rate 2-60 / 3-70
Topography 2-Lvl 3-Lvl
Depth to Water Table 10+
Rock or other impervious formations surface rock.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



(Plot of System)

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Lineal Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by James Hudson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-16-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold