IREDELL COUNTY HEALTH DEPARTMENT

THIS PERMIT VOIDS PREVIOUS ISSUED 04-25-98

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 072390 PIN# 4705 48 4072

OWNER OR CONTRACTOR ERNEST RUNGE DATE 10-22-98

ADDRESS 374 LONG ISLAND ROAD PHONE: Business STATESVILLE NC 28677 Home 873-6645

LOCATION US 64 W TL LIPPARD FARM TR HAPPY ACRES TL TRAILWAY BEAR RIGHT 1ST LOT ON LEFT

SUBDIVISION CASA GRANDE BLOCK / SECTION II LOT 26 LOT AREA 20,250 SF SITE CLASS. PS DESIGN FLOW 240 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1000 Gallons; STB 1012 Date 4-23-98

Pump Tank: ____ Gallons; PT ____ Date ____

Pump Make: ____ Model ____ Serial No. ____

Nitrification Field: No Fields 1 Square Feet EQ. TO 800 Linear Feet 200+

No Lines FOUR Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: 25% REDUCTION GRAVITY

Repair System Description: CONV. GRAVITY

Maintenance Agreement Required: ☐ Yes ☐ No

Gravel Depth SAND 6"

☐ House/Mod. Home ☒ Mobile Home ☐ Business ☐ Other

No. Bedrooms 2 No. Bathrooms 2 No. Employees ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☐ Community

Comments:/Conditions: SYSTEM INSTALLED AS SHOWN PRIOR TO ISSUANCE OF PERMIT

Comments:/Conditions: APPROVED FOR TWO-BEDROOM ONLY

INITIAL SITE SKETCH



AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO INITIAL SITE SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date ____

Improvement Permit by: STEVE HEDRICK date 10-22-98

Authorization to Construct by: STEVE HEDRICK date 10-22-98

Installed by: A-1 BACKHOE

Operation Permit by: STEVE HEDRICK date 10-29-98

Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD