DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: E Runge
ADDRESS:
APPLICANT:
APPLICATION DATE:
DATE EVALUATED: 3/6
PROPOSED FACILITY:
PROPOSED DESIGN FLOW (.1949):
LOCATION OF SITE: lot 23
PROPERTY SIZE: 36'
PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed 14x80

lot 23

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 4-5	0-12	SBK SCL	Fr SS SP		48			0.3
		12-48	SBK C	Fr/Fi SS SP					
			w-m						
2	Linear 5-8	0-48	SBK C	Fr/Fi SS SP	—	48	—	— 0.3	P/S 0.3
			w-m						
3	Linear 4-6	0-	SBK C	Fi/ SS SP	—	48	—	—	0.3 -0.3 P/S
		45-48	SBK C	Fr SS SP					0.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT:

an2508