DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: E Runge
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 3-497
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: _____
LOCATION OF SITE: lot 22
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

360 → 400' - NR

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear -	0-4	~~SBK~~ SCL	~~Fr~~ SS SP	—	48"	—	—	P/S 0.3
		4-24	SBK CL	Fr SS SP					
		24-48	SBK CL/C	Fi/~~Fr~~ SS SP					
2		0-6	~~SBK~~ SCL		—	48"	—	—	P/S 0.3
		6-48	SBK C/C	Fr/Fi SS SP					
3									P/S
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

A0219 8