HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bruce Kuetle _____ AGENT: _____ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 11-5-93
PROPOSED FACILITY: 2 Bedroom house
PROPERTY SIZE: _____

LOCATION OF SITE: Alpine Circle
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	SOIL LANDSCP POS / SLOPE %	HORIZON DEPTH ONLY	SOIL TEXTURE	SOIL STRUCTURE	SOIL CONSIST		
1	3-5% L	0-3"	sil	GR	FI / VFr	-	PS
		3"-48"	SC	SBK	FI / Fr	-	NA
						-	NA
						-	PS
						-	.35
2	3-5% L	0-2"	sil	gr	FI / VFr	-	PS
		2"-48"	C	SBK	FI / Fr	-	NA
						-	NA
						-	PS
						-	.35
3						-	
						-	
						-	
						-	
						-	
4						-	
						-	
						-	
						-	
						-	
5						-	
						-	
						-	
						-	
						-	

AVAILABLE SPACE (%): 5 SITE CLASS: PS SOIL LOADING ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS: None PLAN TYPE: Conventional gravity
EVALUATED BY: Mark J. Dennis OTHER PERSONS: Bruce Kuetle

JAN. 1, 1989 18:00