HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bruce Kuete OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 11-5-93
PROPOSED FACILITY: 2 Bedroom house
PROPERTY SIZE:

LOCATION OF SITE: Alpine Circle
WATER SUPPLY: On-Site Well Comm. Well Public ✓ Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	3-5% L	0-3"	scl	gr	1:1 / vfr	.1942 WETNES CONDITION - P.S.
		3"-48"	sc	sbk	1:1 / fr	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
2	3-5% L	0-2"	scl	gr	1:1 / vfr	.1942 WETNES CONDITION - P.S.
		2"-48"	C	sbk	1:1 / fr	.1943/.1956 SAPROLITE - NA
						.1944 RESTRICTIVE HORIZON - NA
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1945): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE Conventional, gravity.
EVALUATED BY: Michael G. Dennis OTHER(S) PRESENT: Bruce Kuete
COMMENTS:

DRAFT