34294

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 3-17-86 PERMIT NO. _____

OWNER OR CONTRACTOR FANNIE LOVE Home _____

PHONE: Business _____ S. R. No. _____

LOCATION Hwy 90 west - T.L. on Lippard Farm Rd. - go 1/2 mi. - enter driveway on R. bear left at 1st at last lot on left at fence.

SUBDIVISION NAME HAPPY ACRES LOT NO. 29 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1 Character & Porosity of Soil Sandy Loam Suitable

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 5 gal. / sq. ft.

Auto. Dishwasher Yes ( ) No (✓) Topography 2-6%

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 10'+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations none observed


Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

DATE 3-17-86

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold