06789

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BOBBY MASON DATE 6-8-87 PERMIT NO.

PHONE: Business Home

LOCATION Hwy 90 west - T.L. on Lippard Farm Rd. - go approx. ½ mi. to dev. - lot on backside to left. S. R. No.

SUBDIVISION NAME HAPPY ACRES. LOT NO. 24 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prov. Suitable.
Percolation Rate 5 gal./sq. ft.
Topography 2-6% 10 ft
Depth to Water Table
Rock or other impervious formations none observed.

Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field: 3
No. of Lines
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Dennis Hollifield

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-8-87.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold