1092

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BEN WEATHERMAN DATE 7-26-89 PERMIT NO. C 10.

PHONE: Business _____ Home _____

LOCATION Hwy 90W-T/L on Lipps Farm Rd. - ½ mi. on (R) - Enter 2nd - Beer
blue tank still - Left Dat curve. S. R. No. _____

SUBDIVISION NAME HAPPY ACRES LOT NO. 17 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable.
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	2" / 30 min.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10-ft
			Rock or other impervious formations	None encountered.

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Lineal Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by J. C. Forsyth

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-14-89

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold