01847

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Judy Moose

PHONE: Business _____ Home _____ DATE 8/10/84 PERMIT NO. _____


LOCATION 90W Lf on Luppard Farm Road, Go 3/4 mile on Rt into new MH Park Last Lot on Lf

SUBDIVISION NAME Happy Acres LOT NO. 15 S. R. No. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Clay Soil
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate .5gal/ft/day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 18+
Lot Area _____			Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: 3 Lines OC by KS
DO NOT DRIVE OVER DRAIN LINES OR TANK

CERTIFICATE OF COMPLETION BY _____ DATE 8/10/84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold