DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ST-A-48
PROPERTY RECORDED: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Richard Elder OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6-28-93
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
LOCATION OF SITE: Homeplace Lane
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	4-6% L	0"-3"	cl / cr	1:1 / vfr	P.S.	NA	P.S.	NA	.35
		3"-48"	c / sbk	1:1 / fr					
2	4-6% L	0"-4"	cl / cr	1:1 / vfr	P.S.	NA	P.S.	NA	.35
		4"-48"	c / sbk	1:1 / fr					
3									
4									
5									

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
EVALUATED BY Michael L. Dennis OTHER(S) PRESENT: ___
COMMENTS: ___